

Erforderliche Heizleistung und Anschlusswerte für Saunaöfen

Heizleistung in kW	Kabinengröße in m ³ (Grundlage Fertigung nach RAL für Kabinen in Gebäuden)													Mindestquerschnitt der Netzleitung in mm ²		
	3-5	4-6	6-8	7-10	9-14	14-18	18-25	24-30	24-34	35-40	40-50	50-65	65-75	Anschluss an 400 V 3N AC	Anschluss an 230 V AC	Absicherung A
3,0															3 x 1,5 ²	1 x 16
4,5														5 x 2,5 ²		3 x 16
6,0																
7,5																
9,0																
12,0													5 x 4 ²		3 x 25	
15,0																
18,0													5 x 6 ²		3 x 35	
21,0																
24,0													5 x 10 ²		3 x 50	
27,0																
30,0													mind. 5 x 10 ²		3 x 63	
36,0																